

Athul Energy, we stand for Quality, Reliability and Efficiency

No: AEC/GAC/29

18-12-2021

Audit Certificate

This is to certify that M/s Pocker sahib Memorial Orphanage College Thirurangadi, Malapuram have successfully completed the Energy Audit of their buildings and campus conducted on 10th November 2021. They have submitted all necessary data and credentials for scrutiny.

We, Athul Energy Consultants Pvt Ltd, Thrissur congratulate the Management, Executive Director, Principal, staff members and students for the successful completion and participation in the audit report process.

Managing Director

Athul Energy Consultants Pt L

THRISSUR 680 020

Athul Energy Consultants Pvt Ltd CIN: U74999KL2016PTC046898 M info@athulenergy.com Branch Office:

ENERGY AUDIT - 2021



PSMO COLLEGE

TIRURANGADI, MALAPPURAM

EXECUTED BY



ATHUL ENERGY CONSULTANTS PVT LTD

4th FLOOR, CAPITAL LEGEND BUILDING,
KORAPPATH LANE, ROUND NORTH, THRISSUR-680020
Ph: +91 7356111990-6 Web: www.athulenergy.com E-Mail: info@athulenergy.com

November 2021

Athul Energy Consultants Pvt Ltd Energy Audit Report- PSMO College

BRIEFCONTENTS

ANNEXURE-3 32

PREFACE 5 ACKNOWLEDGEMENTS 6 EXECUTIVE SUMMARY 7 ENERGY AUDIT ERROR!

BOOKMARK NOT DEFINED. PSMO COLLEGE- TIRURANGADI ERROR! BOOKMARK NOT

DEFINED. BUILT UP AREA ERROR! BOOKMARK NOT DEFINED. ENERGY ANALYSIS 14

ELECTRICITY CONSUMPTION ANALYSIS 14 ANNEXURE 1 18 ANNEXURE - 2 28



PREFACE 5 ACKNOWLEDGEMENTS 6

EXECUTIVE SUMMARY 7 I. ENERGY SAVING PROPOSALS: 7

ENERGY AUDIT ERROR! BOOKMARK NOT DEFINED. PSMO COLLEGE- TIRURANGADI ERROR!

BOOKMARK NOT DEFINED. BUILT UP AREA ERROR! BOOKMARK NOT DEFINED. ENERGY

ANALYSIS 14

ELECTRICITY CONSUMPTION ANALYSIS 14 I. DESCRIPTION OF ELECTRICITY BILL 14

II. TARIFF RATES ANALYSIS 15 III. SPECIFIC ELECTRICITY CONSUMPTION (KWH/M2) 16

ANNEXURE 1 18 I. CONNECTED ELECTRICAL LOADS 18

ANNEXURE - 2 28 ENERGY SAVING PROPOSALS - 1 28

ENERGY SAVING PROPOSALS - 2 30

ANNEXURE-3 32 I. LIST OF INSTRUMENTS **Error! Bookmark not defined.**II. ABBREVIATIONS 32 III. REFERENCES: 32 IV. CERTIFICATES 33

LISTOFTABLES

| Athul Energy Consul | tants Pvt Ltd Energy Audit Re | eport- PSMO College | | | | |
|---------------------|-------------------------------|---------------------|------------------|-----------|-------|-------------|
| TABLE | 3: | | BIL | L | | ANALYSIS |
| | | | 14 | TABLE | 4: | SPECIFIC |
| ELECTRICITY CO | NSUMPTION | | | 16 | TABL | E 5: LIGHT |
| AND FAN LOA | DS | | | | 18 | TABLE 6: |
| | OTHER POWER LOA | | | | | |
| 7: AIR CONDIT | IONER LOADS | | | | | 26 |
| TABLE | | 8: | | | | UPS |
| | | | | | | |
| | | | | | | |
| EC PROPOSAL 2 | | | | | | 30 TABLE |
| 11: LIFECYCLE DA | ATA OF LIGHT TYPES |) | | | | 31 |
| | L | ISTOFFIGURE | S | | | |
| FIGURE 1: COLLE | GE CAMPUS – SATEL | LITE VIEW (GOOGL | .E) Err o | or! Bookm | ark n | ot defined. |
| FIGURE 5: TARIF | FRATE | | | | | |
| ANALYSIS | | | | 15 | | |



PREFACE

Every institution should be imparting knowledge about the campus environment and its surroundings through activities that follows the principles of sustainability. An energy audit is essential first step to reduce energy cost and greenhouse emissions. Audit is defined as a systematic and implement examination of data statements, records, operations and performance of an enterprise for a purpose. Energy audits is a systematic study or survey to identify how energy being used in its own facility. And identifying the energy savings opportunities in the building Behavioural Change through the student education can provide greatest benefit at least cost. Even small savings in each house holds make dramatic change in the society and for nation. The idea of energy conservation and sustainability will be percolated to society through students will have long standing effect and successful too

This report is compiled by the BEE certified energy auditor along with the project engineers who are experienced in the field of energy, environment and management. The student volunteers made a mammoth contribution with data collection and preparing an initial skeleton for the report.

Page **5** of **34**



Athul Energy Consultants Pvt Ltd Energy Audit Report- PSMO College

ACKNOWLEDGEMENTS

We express our sincere gratitude to the PSMO College, Tirurangadi, Malappuram, for giving us an opportunity to carry out the project of Energy Audit. We are extremely thankful to all the staffs for their support to carry out the studies and for input data, and measurements related to the project of energy audit.

1 Dr. Azeez K Principal

2

Also congratulating our Energy audit team members for successfully completing the assignment in time and making their best efforts to add value.

GREEN AUDIT TEAM

1. Mr. Santhosh A

Registered Energy Auditor of Bureau of Energy Efficiency (BEE – Govt. of India) Accredited Energy Auditor No – EA 7597

2. Mr. Hari Krishnan K

Project Engineer



Athul Energy Consultants Pvt Ltd Energy Audit Report- PSMO College

EXECUTIVE SUMMARY

I. ENERGY SAVING PROPOSALS:

TABLE 1: EXECUTIVE SUMMARY -ENERGY

| Sl. no | Energy conservation measures | Annual Energy Savings | Annual Financial Savings | Investment | Simple payback period |
|-----------|--|-----------------------------|--------------------------------|------------|-----------------------------|
| | | kWh | Rs | Rs | Months |
| 1 | Replacement of T8-110n and T12- 12 No with LED Tube light of 20W | 4500 | 2920 | 36600 | 15 |
| 2 | Replacement of ceiling fan 100 No with BLDC of 35 W | 6750 | 43875 | 350000 | 96 |
| | Total | 11,250 | 46,795 | 386600 | |

II. ENERGY AUDIT SUMMARY & RECOMMENDATIONS

The summary of the report with respect to each section is as follows.

1. Equipment and Utility

Light loads: Majority of the lighting fixtures are fluorescent type (T12 and T8). By replacing these loads with LED light fittings will reduce the overall power consumption. **Ceiling fan**

loads: Ceiling fans are installed in majority of the areas by replacing it with Brushless DC fans which consumes in the range of 25 to 30W at full speed, instead of 70W in normal fans, will reduce the power consumption considerably. Also, while purchasing new fans priority should be given for BLDC

Page 7 of 34

Athul .

Athul Energy Consultants Pvt Ltd Energy Audit Report- PSMO College III. AUDIT SUMMARY – ACTIONS

The actionable summary of the audit report is given in the table below.

TABLE 2: ENERGY AUDIT SUMMARY - ACTIONS

| Sl No: | Particulars | Location | Action to be taken | Remarks |
|--------|--|---------------------------------------|---|--|
| 1 | Energy efficiency – Replacement of ceiling fans with BLDC fans | Office, staff rooms, Classrooms | Change the existing old ceiling fans with BLDC fans | Power Consumpti on will get reduced |
| 2 | Energy efficiency – Replacement of fluorescent lights with LED lights | Office, staff rooms, Classrooms | Change the existing lights with LED lights | Power Consumpti on will get lowered |

IV. ENERGY PERFORMANCE INDEX

EPI is based on the energy consumption during November 2020 to October 2021. The futuristic energy consumption after the implementation of energy saving proposals is given in the tables below.

TABLE 3: ENERGY INDEX

| Parameters | Values |
|--|--------|
| Present Annual electricity consumption(kWh/year) | 43028 |
| Present annual specific electricity consumption (kWh/m2) | 3.70 |
| Present CO ₂ emission (Tons/year) | 21.514 |
| After Energy Saving Implementation | |
| Expecting annual electricity consumption (kWh/year) | 31778 |

| Expecting annual specific electricity consumption (kWh/m2) | 2.73 |
|--|-------|
| Electricity and CO2 emission reduction % | 26.15 |

Page 8 of 34



Athul Energy Consultants Pvt Ltd Energy Audit Report- PSMO College

INTRODUCTION

I. ENERGY AUDIT

An energy audit is a key to assessing the energy performance of an energy consuming facility and for developing an energy management program. The typical steps of an energy audit are:

- Preparation and planning
 - Data collection and review
 - •Plant surveys and system measurements
 - •Observation and review of operating practices
 - •Data documentation and analysis
 - •Reporting of the results and recommendations

1.1. Definition of energy auditing

In the Indian Energy Conservation Act of 2001 (BEE 2008), an energy audit is defined as: "The verification, monitoring and analysis of the use of energy and submission of technical report containing recommendations for improving energy efficiency with cost-benefit analysis and an action plan to reduce energy consumption."

1.2. Objectives of Energy Auditing

The objectives of an energy audit can vary from one plant to another. However, an energy audit is usually conducted to understand how energy issued within the plant and to find opportunities for improvement and energy saving. Sometimes, energy audits are conducted to evaluate the effectiveness of an energy efficiency project or program. In Mount Zion College as per the request from the institution, we have assessed the energy consumption and saving opportunities at present scenario.

Methodology for the study

The methodology adopted for energy audit starts from historical energy data analysis, power quality analysis, monitoring of operational practices, system evaluation, cost benefit analysis of the energy conservation opportunities, and prepare plan for implementation. The proposals given in the report includes economical energy efficiency measures to reduce facilities unnecessary energy consumption and cost. The energy conservation options, recommendations and cost benefit ratio, indicating payback period are included in this report.

Scope of Work

The Scope of Work includes:

- 1. Historical energy data analysis.
- 2. Electrical, Mechanical and Thermal energy analysis.
- 3. Power Quality Analysis.
- 4. Identification of Energy saving opportunities.

II. PSMO COLLEGE- TIRURANGADI

Pocker Sahib Memorial Orphanage College was established in July, 1968 as an aided junior college, affiliated to the University of Kerala under the management of the Tirurangadi Muslim orphanage committee (Regd.). Though the college was initially intended for the educational advancement of the orphans in the Muslim community, presently it fulfils the educational aspirations of students from all communities. The campus is located 13 km away from the University of Calicut, at an earshot distance from Kakkad, on the Calicut – Thrissur National Highway. It is just 8 km from Parappanangadi Railway station, 13 km from Calicut International Airport and 25 km from Malappuram District Head Quarters.

Vision

To achieve national and international recognition as a premier academic institution, through an extraordinary, student centered, value based, teaching learning practices and quality Research output.

Mission

- To align the academic endeavours of the college with the best nationally and globally
- To collaborate with institutions of eminence leading to elevated student experiences
- To establish student-centred instructional ecosystem with active learning practices
 To provide top-class exposure to research in terms of thought and material support



FIGURE 1: COLLEGE CAMPUS - SATELLITE VIEW (GOOGLE)

| Sl.No: | Particulars | Details |
|--------|---------------------------|---|
| 1 | Name of the College | PSMO College |
| 2 | Address | PSMO College Tirurangadi Malappuram, Kerala 676 306, India |
| 3 | Contact Person | |
| 4 | E-mail ID | mail@psmocollege.ac.in |
| 5 | Website Details | www.psmocollege.ac.in |
| 6 | Type of college | Affiliated to Calicut University |
| 7 | Annual Working Days | 210 |
| 8 | No: of Shifts | 1 |
| 9 | No : of students | 1876 |
| 10 | No: of teaching staff | 78 |
| 11 | No: of non-teaching staff | 30 |
| 12 | Total campus area(acres) | 20.92 |
| 13 | Total built up area(M²) | 11634 |

Page **11** of **34**



Athul Energy Consultants Pvt Ltd Energy Audit Report- PSMO College

IV. LOAD BALANCE- ELECTRICAL

Load balance among the connected loads is given in the figure below. The office equipment and the light – fan loads share 67% of the total connected load in the building.

Load balance - Total kW - 111.8 kW

BALANCE
Light & Fan
Air conditioner Office
Equipment Other
34%
33%
load



Athul Energy Consultants Pvt Ltd Energy Audit Report- PSMO College SINGLE LINE DIAGRAM

The electrical single line diagram of the college is given below:



Page 13 of 34

Athul Energy Consultants Pvt Ltd Energy Audit Report- PSMO College

ENERGY ANALYSIS

The different type's energy usage is given in this section. The major source of energy to the college is electricity. Other forms come in the form of LPG, petrol and diesel.

ELECTRICITY CONSUMPTION ANALYSIS

The major source of electricity to the college is the electrical connection from the KSEB. A diesel generator is provided in the college, but it is only used during power failures.

I. DESCRIPTION OF ELECTRICITY BILL

Base line data given below is based on the Electricity bill provided by the supplier of electricity to the College. Details obtained from the KSEB bill for the month of April 2020 to March 2021 is as follows in the Table.

| TABLE 5: KSEB BILL ANALYSIS |
|-----------------------------|
| |
| Consumer No 1165782000874 |
| Connected Load(kW) 73.36 |

| Tariff LT-6A/Three |
|--|
| Average monthly consumption (kWh) 2822 |
| Average Fixed charges (Rs) 4810 |
| Average Energy charge (Rs) 23307 |

Page **14** of **34**

Athul Energy Consultants Pvt Ltd Energy Audit Report- PSMO College

II. TARIFF RATE ANALYSIS

The monthly energy and demand charges for the period November 2020 to October 2021 is represented in Fig.

TARIFF RATE




FIGURE 3: TARIFF RATE ANALYSIS

Inference i. Average fixed charges for the past one year were Rs 4.810/ per month and energy charges was Rs 23.307/ per month.

ii. The energy charges come about 76% of the total bill.

III. SPECIFIC ELECTRICITY CONSUMPTION (KWH/M2)

The electricity consumption from the March 2020 to Aug 2021 has been taken for the benchmarking. Here the comparison is done with electricity consumption and the building area which is the average of each month. The below table shows the specific electricity consumption of PSMO College **TABLE 6**:

SPECIFIC ELECTRICITY CONSUMPTION

| Month | Electricity Consumption | Building Area | SEC |
|--------|--------------------------------|----------------------|---------------|
| | kWh | Sq. Metre | kWh/Sq. Metre |
| Nov-20 | 2796 | 11634 | 0.24 |
| Dec-20 | 2412 | 11634 | 0.21 |
| Jan-21 | 4902 | 11634 | 0.42 |
| Feb-21 | 5034 | 11634 | 0.43 |
| Mar-21 | 5814 | 11634 | 0.50 |
| Apr-21 | 5250 | 11634 | 0.45 |
| May-21 | 1922 | 11634 | 0.17 |
| Jun-21 | 2082 | 11634 | 0.18 |
| Jul-21 | 2544 | 11634 | 0.22 |
| Aug-21 | 2724 | 11634 | 0.23 |
| Sep-21 | 3902 | 11634 | 0.34 |
| Oct-21 | 3646 | 11634 | 0.31 |
| Avg | | | |

Specific Electricity Consumption
0.60 0.50 0.40 0.30 0.20 3000 2000 1000 0
0.10 0.00
7000 6000 5000 4000

Nov-20 Dec-20 Jan-21 Feb-21 Mar-21 Apr-21 May-21 Jun-21 Jul-21 Aug-21 Sep-21 Oct-21 kWh 2796 2412 4902 5034 5814 5250 1922 2082 2544 2724 3902 3646 SEC 0.24 0.21 0.42 0.43 0.50 0.45 0.17 0.18 0.22 0.23 0.34 0.31

FIGURE 4: SPECIFIC ELECTRICITY CONSUMPTION

Page 16 of 34


Athul Energy Consultants Pvt Ltd Energy Audit Report- PSMO College

RENEWABLE ENERGY

The Sun is an inexhaustible, reliable and non-polluting source of power. Since the inception of life on earth, the only energy that was available came from the sun. The time is now approaching when mankind will again depend upon the sun as dominant energy source. We are aware that fossil fuels are not going to last forever. A growing worldwide concern for conservation of energy has reignited our interest in ecologically sustainable materials, processes and sources of energy. The advantages of solar power are:

- The solar energy is more evenly distributed in the world than wind or bio-mass. It is well proven and demonstrated technology
- It promises to be most cost effective renewable power at high volumes.
- The solar energy potential in India is immense due to its convenient location near the Equator. India receives nearly 3000 hours of sunshine every year, which is equivalent to 5000 trillion kWh of energy.

PSMO College has installed 15kw ongrid solar system. Polycab inverter of rating 15 kva and xx number of solar panels are being used by the system. Approximately xx kwh is generated per day by the solar system. During the low electricity consumption period the surplus solar energy generated is back fed to KSEB, which in turn result in monetary benefits



Page **17** of **34**

Athul Energy Consultants Pvt Ltd Energy Audit Report- PSMO College

ANNEXURE 1

I. CONNECTED ELECTRICAL LOADS

I. LIGHT AND FAN LOADS

TABLE 7: LIGHT AND FAN LOADS

| IADLE 7. LIGHT | mind imin | поль | | | | | | | | | | | |
|---------------------|---------------|------|----|-----|-----|-----------------------|-------------|--------------------------|-----|-----|-----|-----|--|
| Location | T12 | Т8 | Т5 | CFL | CFL | Incandesc ent Bulb | LED bulb | LED TUBE LIGH T | LED | LED | LED | LED | |
| Power (W) | 40 | 36 | 28 | 23 | 12 | 60 | 9 | 20 | 100 | 9 | 5 | 11 | |
| | Main Building | | | | | | | | | | | | |
| Room No.77 | | | | | | | | | | 2 | | | |
| Room No.76 | | | | | | | | | | 2 | | | |
| Room No.75 | | | | | | | | | | 2 | | | |
| Research library | | 2 | | | 1 | | | | | | | | |
| PG dept Library | | 4 | | | | | | | | | | | |
| History | | 2 | | | | | | | | | | | |
| Room No.71 | | | | | | | | 1 | | | | | |
| Room No.70 | | | | | | | | 1 | | | | | |
| Room No.69 | | | | | | | | 1 | | | | | |
| Room No.68 | | | | | | | | 2 | | | | | |

| Room No.67 | | | | 1 | | | |
|------------|---|--|--|---|---|--|--|
| Room No.66 | 2 | | | 1 | | | |
| Room No.65 | 1 | | | | 1 | | |
| Room No.64 | 3 | | | | | | |
| Room No.63 | | | | 2 | | | |

Page **18** of **34**

| Location | T12 | Т8 | Т5 | CFL | CFL | Incandesc ent Bulb | LED bulb | LED TUBE LIGH T | LED | LED | LED | LED | |
|---------------|-----|----|----|-----|-----|-----------------------|-------------|--------------------------|-----|-----|-----|-----|---|
| Power (W) | 40 | 36 | 28 | 23 | 12 | 60 | 9 | 20 | 100 | 9 | 5 | 11 | |
| Room No.62 | | | | | | | | | | | | | |
| Room No.61 | | | | | | | | | | | | | L |
| Room No.60 | 2 | 6 | | | | | | 1 | | | | | |
| Room No.58 | | | | | | | | | | | | | |
| Room No.57 | | 2 | 2 | | | 1 | | | | | | | |
| Room No.56 | | 2 | | | | | | | | | | | |
| Room No.55 | | | | | | 1 | | | | | | | |
| Room No.53 | 1 | 6 | | | | | 1 | | | | | | |
| Room No.52 | | 1 | | | | | | | | | | | |
| Office | 1 | 5 | | 1 | | | | 1 | | | | | |
| Room No.48 | | 2 | | | | | | | | | 10 | 1 | |
| Room No.47 | | 2 | | | | 1 | | | | | | | |
| Room No.45 | | 4 | | | | | | 3 | | | | | |
| Room No.44 | | 5 | | | | | | | | | | | |
| Room No.41 | | 1 | | | | | | 1 | | | | | |
| Room No.40 | | 2 | | | | | | | | | | | |
| Room No.39 | | 1 | | | | | 1 | | | | | | |
| Room No.38 | | | | | | | | 8 | | | | | |
| Room No.37 | | | | | | | | 8 | | | | | |
| Room No.36 | | | | | 2 | | | | | | | | |
| Room No.35 | | | | | 1 | | | | | | | | |
| Principal | | | | | | | | | | | 4 | | |
| Visitors room | | 1 | | | | | | | | | | | |
| Room No.34 | | | | | 1 | | | | | | | | T |

| Room No.33 | 2 | | 1 | 8 | 2 | | | |
|------------|---|--|---|---|---|--|--|--|
| Room No.32 | | | | | | | | |

Page **19** of **34**

| Athul Energy Co | nsultants | Pvt Ltd En | ergy Audit | Report- PS | MO Colleg | e | | | | | | | _ |
|------------------------------|-----------|------------|------------|------------|-----------|-----------------------|-------------|--------------------------|-------|-----|-----|-----|----------|
| Location | T12 | Т8 | Т5 | CFL | CFL | Incandesc ent Bulb | LED bulb | LED TUBE LIGH T | LED | LED | LED | LED |] |
| Power (W) | 40 | 36 | 28 | 23 | 12 | 60 | 9 | 20 | 100 | 9 | 5 | 11 | - |
| Room No.31 | | 2 | 1 | | | | | 1 | | | | | |
| Room No.30 | | 1 | | | | | | 1 | | | | | |
| Room No.29 | | 1 | | | | | | | | | | | |
| Room No.27 | | 1 | | 2 | | | | | | 3 | | | |
| Research lab chemistry | | | | | | | | 6 | | | | | |
| Dept of chemistry | | 1 | | | | | 1 | 3 | | | | | |
| Class room | | | | | | | | 2 | | | | | |
| Class room | | 1 | | | | | | 1 | | | | | |
| Class room | | | | | | | | 4 | | | | | |
| Dept of Maths | | 1 | | | | | | 1 | | | | | |
| Class room | | | | | | | | 2 | | | | | |
| Dept of Botany | | 2 | | | | | | | | | | | |
| Bsc lab | 4 | 5 | | | | 1 | | | | | | | |
| Botany classroom | | 1 | | | | | | 1 | | | | | |
| Cooperative store | | | | | | | | 7 | | | | | |
| | | | | | | | Phys | ical Educ | ation | | | | |
| PE | | 2 | | | 2 | | | | | | | | |
| | | | | | | <u> </u> | , | Canteen | ı | | 1 | | |
| Canteen | | | | | | 1 | 1 | 3 | | | | | |
| | | 1 | ı | 1 | 1 | _ | 1 | Staff Clul | b | Ι | | | <u> </u> |
| Staff Club | | | | | | | | 4 | | | | | |
| | | 1 | ı | 1 | ı | | Li | brary Blo | ock | 1 | ı | | 1 |
| Hall | | | | | | | | 8 | | | | | |
| Childline room | | | | | | | | 1 | | | | | |

Athul Energy Consultants Pvt Ltd Energy Audit Report- PSMO College T12 Т8 **T5** CFL **CFL** Incandesc LED LED LED LED LED LED Location ent Bulb bulb TUBE LIGH T 40 28 23 12 60 9 100 9 5 11 Power (W) 36 20 Research 4 **Msc Botany** 8 23 13 Library Library 10 6 12 3 **NCC Bhavan** Auditorium Auditorium 1 8 11 1 5 1 Hostel 2 8 Women's Hostel 56 2 16 IGNOU Block 1 27 Ladies corner 7 **Science Block** Room No.80 2 5 1 Bsc. Che lab 2 Room No.85 24 Room No.84 1 1 Room No.83 1 1 Room No.82 4 Room No.90 2 2 Room No.89 2 Room No.88 2 Room No.87

Page **21** of **34**

Athul Energy Consultants Pyt Ltd Energy Audit Report- PSMO College

| Athul Energy Co | onsultants I | Pvt Ltd En | ergy Audit | Report- PS | SMO Colleg | e | | | | | | | |
|-----------------|--------------|------------|------------|------------|------------|-----------------------|-------------|---------------------|-----|-----|-----|-----|---|
| Location | T12 | Т8 | Т5 | CFL | CFL | Incandesc ent Bulb | LED bulb | LED TUBE LIGH | LED | LED | LED | LED | l |
| | | | | | | | | • | | | | l ' | |

| Total (kW) | 36.699 | | | | | | | | | | | | |
|-------------|--------|-------|-------|-------|------|-----|------|------|-----|-------|------|-------|-----|
| | | | | | | | | | | | | | |
| | 0.48 | 8.172 | 0.896 | 0.345 | 0.18 | 0.3 | 0.27 | 2.28 | 0.1 | 0.306 | 0.07 | 0.011 | 0. |
| | 12 | 227 | 32 | 15 | 15 | 5 | 30 | 114 | 1 | 34 | 14 | 1 | _ : |
| Room | | | | | | | | | | | | | |
| Arabic Dept | | 3 | | | | | | | | | | | |
| Room No.86 | | 2 | | | | | | | | | | | |
| Power (W) | 40 | 36 | 28 | 23 | 12 | 60 | 9 | 20 | 100 | 9 | 5 | 11 | |

II. COMPUTER AND OTHER POWER LOADS

TABLE 8: COMPUTER AND OTHER POWER LOADS

| TABLE 8: CO | MPUT | ER AND OT | THER POV | <u>WER LOAI</u> | <u>JS</u> | | | | | | | | |
|----------------------|---------|---------------|----------------------|-----------------|----------------------|-----------------------|-------------------|-------------------------|------|---------|---------------|----------|----------------|
| Location | PC | Project or | Laser Print er | Scann er | Xerox Machi ne | 3 in 1 Print er | Refrige rat or | Inducti on Cooker | TV | TV | Amplifi er | Ove n | Muff l e |
| | | | | | | | | | | | | | furna ce |
| Power(W) | 20 0 | 150 | 400 | 80 | 450 | 450 | 250 | 1500 | 80 | 12 0 | 350 | 180 0 | 300 0 |
| | | | | | | | | Main buil | ding | • | | | |
| Room No.75 | | 1 | | | | | | | | | | | |
| Researc h library | 4 | | | | | 1 | | | 1 | | | | |
| Room No.65 | | 1 | | | | | | | | | | | |

Page **22** of **34**

| Athul Ene | rgy Cons | sultants Pvt L | td Energy 1 | Audit Report | t- PSMO Coli | lege | | | | | | | |
|---------------|----------|----------------|----------------------|--------------|----------------------|-----------------------|-------------------|-------------------------|----|---------|---------------|----------|-------------------------------|
| Location | PC | Project or | Laser Print er | Scann er | Xerox Machi ne | 3 in 1 Print er | Refrige rat or | Inducti on Cooker | TV | TV | Amplifi er | Ove n | Muff l e furna ce |
| Power(W) | 20 0 | 150 | 400 | 80 | 450 | 450 | 250 | 1500 | 80 | 12 0 | 350 | 180 0 | 300 0 |
| Room No.64 | | | | | | 1 | | | | | | | |
| Room No.60 | 1 | | | | | | 2 | | | | | 2 | 1 |
| Room No.58 | | 1 | | | | | | | | | | | |
| Room | 5 | | 1 | | | 1 | | 1 | | | | | |

| No.57 | | | | | | | | | | |
|---------------|----|---|---|---|---|---|--|---|---|--|
| Office | 9 | | 6 | | 1 | | | | | |
| Room No.48 | 1 | | 2 | | | | | | | |
| Room No.45 | 30 | | 1 | 1 | 1 | | | | | |
| Room No.43 | | 1 | | | | | | | | |
| Room No.44 | 48 | 1 | | | | | | | | |
| Room No.38 | | 1 | | | | | | | 1 | |
| Principa l | | | | | | 1 | | 1 | | |

Page **23** of **34**

Athul Energy Consultants Pvt Ltd Energy Audit Report- PSMO College

| Location | PC | Project or | Laser Print er | Scann er | Xerox Machi ne | 3 in 1 Print er | Refrige rat or | Inducti on Cooker | TV | TV | Amplifi er | Ove n | Muff l e furna ce |
|-------------------------|---------|---------------|----------------------|-------------|----------------------|-----------------------|-------------------|-------------------------|----|---------|---------------|----------|-------------------------------|
| Power(W) | 20 0 | 150 | 400 | 80 | 450 | 450 | 250 | 1500 | 80 | 12 0 | 350 | 180 0 | 300 0 |
| Room No.32 | | 1 | | | | | | | | | | | |
| Room No.31 | 1 | | 1 | | | | | | | | | | |
| Room No.27 | | | | | | | 1 | | | | | 1 | |
| Class room | | 1 | | | | | | | | | | | |
| Dept of Maths | 1 | | 1 | | | | | | | | | | |
| Bsc lab | | | | | | | 2 | | | | | | |
| Botany classroo m | | 1 | | | | | | | | | | | |
| Coperati ve store | | | | | | | | | | | | | |
| | | | <u> </u> | | | <u> </u> | | Cantee | en | | | | |

| | | | 1 | | | | |
|--|--|--|---|-----------|------|--|--|
| | | | | Staff clu | ıb | | |
| | | | | | 1 | | |
| | | | | Library b | lock | | |

Page **24** of **34**

| Athul Ene | rgy Cons | sultants Pvt L | td Energy | Audit Repor | t- PSMO Col | lege | | | | | | | |
|-----------------------|----------|----------------|----------------------|-------------|----------------------|-----------------------|-------------------|-------------------------|-------|---------|---------------|----------|-------------------------|
| Location | PC | Project or | Laser Print er | Scann er | Xerox Machi ne | 3 in 1 Print er | Refrige rat or | Inducti on Cooker | TV | TV | Amplifi er | Ove n | Muff l e furna |
| Power(W) | 20 0 | 150 | 400 | 80 | 450 | 450 | 250 | 1500 | 80 | 12 0 | 350 | 180 0 | 300 |
| Childli ne room | 1 | | 1 | | | | | | | | | | |
| | 2 | | | | | | | | | | | | |
| | 41 | | | | | | | | | 1 | | | |
| | | | | | | | | IGNOU B | lock | | | | |
| | 1 | | | | | | 1 | | | | | | |
| | | | | | | | | Science B | Block | | | | |
| Bsc. Che lab 2 | | | | | | | | | | | | | |
| Room No.85 | | 1 | | | | | | | | | 1 | | |
| Room No.82 | | | 1 | | | | | | | | | | |
| Room | | 1 | | | | | | | | | | | |
| | 14 1 | 9 | 14 | 1 | 2 | 3 | 7 | 1 | 1 | 2 | 1 | 4 | 1 |
| | 28. 2 | 1.35 | 5.6 | 0.08 | 0.9 | 1.35 | 1.75 | 1.5 | 0.0 | 0.2 | 0.35 | 7. 2 | 3 |
| Total (KW) | | | | | | | | • | 55.30 |) | | | |

TABLE 9: AIR CONDITIONER LOADS

| Location | Make | Туре | Capacity | EER | Star | Rated |
|------------|------------|-------|----------|------|---------|-----------|
| | | | (Tr) | | rating | power (W) |
| Principal | | Split | 1 | | 3 | 1000 |
| IQAC | Mitsubishi | Split | 1 | | 3 | 1000 |
| Room No.45 | Carrier | Split | 1.5 | | 3 | 1500 |
| Room No.45 | Carrier | Split | 1.5 | | 3 | 1500 |
| Room No.44 | Voltas | Split | 1.5 | | No star | 1500 |
| Room No.44 | Voltas | Split | 1.5 | | No star | 1500 |
| Library | Voltas | Split | 2 | | 3 | 2200 |
| Library | Voltas | Split | 2 | | 3 | 2200 |
| Library | | Split | 1 | | 3 | 1000 |
| Room No.85 | Mitsubishi | Split | 2 | 3.33 | 5 | 2160 |
| Room No.85 | Mitsubishi | Split | 2 | 3.33 | 5 | 2160 |
| Room No.85 | Mitsubishi | Split | 2 | 3.33 | 5 | 2160 |
| Total | 19.88kW | | | | | |

Page **26** of **34**

Athul Energy Consultants Pvt Ltd Energy Audit Report- PSMO College

IV. UPS

TABLE 10: UPS DETAILS

| | | | | _ |
|--------------------|---------|-----|----------------------|---------|
| Location | Make | KVA | Battery Make/Type/No | Volt/AH |
| Room No.60 | | 2 | Tubular/2 | 12/130 |
| Room No.57 | Hykon | 1 | Exide/Tubular/4 | |
| Room No.57 | Hykon | 2 | Exide/Tubular/4 | |
| Room No.53 | Supra | 3 | Exide/Tubular/4 | 12/100 |
| Office | Supra | 3 | Exide/Tubular/4 | 12/100 |
| Room No.45 | Hykon | 7.5 | Exide/Tubular/12 | 12/150 |
| Room No.44 | Supra | 7.5 | Exide/Tubular/16 | |
| Dept. of chemistry | Supra | 3 | Tubular/2 | 12/100 |
| Bsc. Lab | Hykon | 1 | Tubular/2 | |
| Library | Zenster | 3 | Tubular/6 | 12/150 |
| Library | Supra | 2 | Tubular/4 | 12/100 |

| Digital Library | Hykon | 7.5 | Tubular/15 | 12/100 |
|-----------------|---------|-----|------------|--------|
| Digital Library | Hykon | 7.5 | | |
| Arabic dept. | Zenster | 1.5 | | |

Page **27** of **34**

Athul Energy Consultants Pvt Ltd Energy Audit Report- PSMO College ANNEXURE - 2

ENERGY SAVING PROPOSALS - 1

REPLACEMENT OF CEILING FANS WITH ENERGY EFFICIENT BLDC FANS

Background

A BLDC fan takes in AC voltage and internally converts it into DC using SMPS. The main difference between BLDC and ordinary DC fans is the commutation method. A commutation is basically the technique of changing the direction of current in the motor for the rotational movement. In a BLDC motor, as there are no brushes, so the commutation is done by the driving algorithm in the Electronics. The main advantage is that over a period, due to mechanical contact in a brushed motor the commutators can undergo wear and tear, this thing is eliminated in BLDC Motor making the motor more rugged for long-term use. To explain, BLDC technology in simpler terms, BLDC uses a combination of Permanent Magnets and Electronics to achieve the kind of efficiency and performance, it delivers. A BLDC fan composes of 3 main components: - 1. Stator 2. Rotor 3. Electronics

Proposal

Replace the ceiling fans with BLDC in the as per preference of operating hours as office areas., staff rooms and in security cabin and in hostels the calculation for the savings is given in the table. TABLE 11:

EC PROPOSAL 1

| Existing Ceiling Fans | Watts | 60 |
|--|--------|----------|
| Proposed BLDC Fans | Watts | 30 |
| Difference in Wattage | Watts | 30 |
| Avg No: of working hours/day | Hrs. | 9 |
| No: of working days per year (Average) | Days | 250 |
| No: of working hours per annum | Hrs. | 2250 |
| Number of Fans operating | Nos | 100 |
| Energy Saving per Annum | kWh | 6750 |
| Cost per kWh | Rs | 6.50 |
| Annual Financial Savings | Rs | 43875.00 |
| Cost of BLDC Fans | Rs | 3500 |
| Investment for Fans | Rs | 350000 |
| Simple Payback period | Months | 96 |

Actual savings and comparison chart with normal, star rated and BLDC fans. Actual savings and simple payback period will be less for BLDC fans.

| Туре | Power at Various Speeds | | | | | |
|--|-------------------------|-----------|-----------|-----------|-----------|-----------------|
| | 1 | 2 | 3 | 4 | 5 | Max (M3/Min) |
| Regular Ceiling Fan | 14 | 25 | 39 | 48 | 76 | 230 |
| 5 Star rated Fan | 13 | 24 | 30 | 40 | 55 | 210-220 |
| BLDC Fan | 3.8 | 7.7 | 13.8 | 22.7 | 35.8 | 230 |
| % Variation of BLDC fan with Ceiling fan in power | 72.8 5 | 69.2 | 64.6 2 | 52.7 1 | 52.8 9 | |
| % Variation of BLDC fan with 5 Star rated fan in power | 70.7 7 | 67.9 2 | 54 | 43.2 5 | 34.9 1 | |
| Saving in power for Ceiling fan and BLDC | 10.2 | 17.3 | 25.2 | 25.3 | 40.2 | |
| Saving in power for 5 Star rated Ceiling fan and BLDC | 9.2 | 16.3 | 16.2 | 17.3 | 19.2 | |

Page **29** of **34**

Athul Energy Consultants Pvt Ltd Energy Audit Report- PSMO College

ENERGY SAVING PROPOSALS – 2

REPLACEMENT OF FLUORESCENT TUBES WITH ENERGY EFFICIENT LED LIGHTS

At present LED lights are used in very few areas. Replacement of Fluorescent lights to be done in phased manner with LED lights.

TABLE 12: EC PROPOSAL 2

| Particulars | Units | T8 | T12 |
|--|-------|-----------|------|
| Existing Fluorescent lights | Watts | 36 | 40 |
| Proposed LED light | Watts | 20 | 20 |
| Difference in Wattage | Watts | 16 | 20 |
| Avg No: of working hours/day | Hrs | 9 | 9 |
| No: of working days per year (Average) | Nos | 250 | 250 |
| No: of working hours per annum | Hrs | 2250 | 2250 |
| Number of Lights operating for change | Nos | 110 | 12 |

| Energy Saving per Annum | kWh | 3,960.00 | 540.00 |
|---------------------------|--------|-----------|----------|
| Cost per kWh (Average) | Rs | 6.50 | 6.50 |
| Annual Financial Savings | Rs | 25,740.00 | 3,510.00 |
| Cost of LED light | Rs | 300 | 300 |
| Investment for LED lights | Rs | 33,000 | 3,600 |
| Simple Payback period | Months | 15 | 12 |

SUMMARY

| Particulars | Unit | Details |
|--------------------------------|--------|---------|
| Total Annual energy savings | kWh | 4500 |
| Total Annual Financial savings | Rs | 29,250 |
| Total Investment | Rs | 36,600 |
| Simple payback period | Months | 15 |

Page 30 of 34

Athul Energy Consultants Pvt Ltd Energy Audit Report- PSMO College Reason for change in the lighting system

Lighting quality can have a dramatic influence on the attitude and performance of working persons, if they have an environment that with proper uniform lighting.

In addition to the lumens per watt which is a lighting quantity calculation lighting quality and life of lighting system is also to be considered.

Lighting quality can be divided into Uniformity, Glare, Colour rendering Index, coordinated colour temperature.

In case of consistency and in uniformity, the life time of LED is far better than CFL s and FTLs. Deterioration of lumens or lux level in FTLs and CFL are more as compared with LED which is consistent during in its life time.

Considering VCP (Visual Comfort Probability) LED is better option than FTLs and CFL because the glare value is lesser.

The LED are whitish in colour than FTLs which is giving a better feeling of brightness to the persons occupied or working

CCT of LED is 5000k which is white as compared with lesser CCT for FTLS of $4500\,k$ There is no mercury content in the LED as compared with CFL and FTL s hence it is environmentally supportive.

The life cycle data of tube lights with LED is given in the table below.

TABLE 13: LIFECYCLE DATA OF LIGHT TYPES

| Typical Cost per No: of lamps Replaceme Approximate Total life in lamp required during nt cost per maintenance cost p | - |
|---|---|
| Hours LED lifetime (led lamp expense for lam) 60,000 replacement Hours) | |

| T12 | 5000 | 45 | 12 | 540 | 500 | 1040 |
|-----|-------|-----|----|------|-----|------|
| Т8 | 5000 | 45 | 12 | 540 | 500 | 1040 |
| Т5 | 5000 | 100 | 12 | 1200 | 500 | 1700 |
| LED | 60000 | 800 | 1 | 800 | 0 | 800 |

Page **31** of **34**

Athul Energy Consultants Pvt Ltd Energy Audit Report- PSMO College

ANNEXURE-3

I. ABBREVIATIONS

AVG : Average

BEE: Bureau of energy efficiency

CO2: Carbon dioxide

KSEB: Kerala State Electricity Board.

DB : Distribution Board EC : Energy Conservation

IEEE: The Institute of electrical and electronics engineers IS: Indian Standard

kL: kilo Liter

KVA: kilo Volt Ampere

kVAh : kilo volt Ampere Hour

kVAr : kilo volt ampere

kW: kilo Watts kWh: kilo watt hour LT: Low tension MAX: Maximum

NSS : National Service Scheme SLD : Single Line Diagram

II. REFERENCES:

• Handbook on energy audit and environment management by TERI. • Bureau of Energy Efficiency (BEE) books for certification of Energy Auditors & Managers.

Athul Energy Consultants Pvt Ltd Energy Audit Report- PSMO College III. CERTIFICATES

I. BEE Accreditation Certificate

